



कार्यालय अधिशासी अभियन्ता
खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), कासगंज
कलैक्ट्रेट परिसर, सोरों रोड़ प्रहलादपुर, कासगंज, 207123

पत्रांक 580 / प्रयोगशाला (स्टा) / 22 दिनांक :- 25/03/2026

सेवा में,

प्रधानाचार्य,

एस०वी०डी० इण्टर नेशनल स्कूल,

जलेसर रोड़, अवागढ़ जनपद एटा।


विषय:- जल नमूना जाँच रिपोर्ट के सम्बंध में।

उपरोक्त विषयक आप द्वारा लिखित पत्र दिनांक 23.03.2026 के क्रम में आपके द्वारा एस०वी०डी० इण्टर नेशनल स्कूल, जलेसर रोड़ अवागढ़ एटा हेतु जनपदीय प्रयोगशाला एटा में जमा कराये जल नमूना की जाँच की गयी जो कि मानक के अनुरूप है।

अतः जल श्रोत स्कूल के प्रयोग हेतु उपयुक्त है।

संलग्नक उपरोक्तानुसार

भवदीय


अधिशासी अभियन्ता

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **580**

Dated: **25-03-2026**

It is certified that an inspection team headed by **Sunil Kumar Junior Engineer** from **U.P. Jal Nigam (Rural) Etah** PHED inspected the **SVD International School, Jalesar Road, Awagarh Etah** on **24-03-2026** and on the basis of Water Test Report (Attached) bearing no **U2639331S35648101** date **25-03-2026** of **District Level Water Analysis Laboratory U.P. Jal Nigam (Rural) Etah** (PHED Lab) certified that **SVD International School, Jalesar Road, Awagarh Etah** has safe drinking water facilities for the students and members of staff of the institution.

This certificate is valid till **06 Months**

Signature with Seal 

Name **Vishwjeet**

Designation **Executive Engineer**

Name & Address of the Office / Department

U.P. Jal Nigam (Rural) Etah

To

SVD International School, Jalesar Road, Awagarh Etah

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies ✓

Jal Jeevan Mission

Har Ghar Jal



District Level Water Analysis Laboratory , U.P Jal Nigam (Rural), Etah

Office of Executive Engineer, Construction unit, U.P Jal Nigam, Nehru Nagar, Shashtripuram, GT Road, Etah. Pin- 207001 (Test Address only)

Test report

Sample
Id:

U2639331535648101

User Information

Name: SVD International School

Mobile: 9761667625

Email: principalsvdawagarh@gmail.com

Pin
Code: 207301

Full
Address: Village- Awagarh , Gram Panchayat- AWAGARH, Block- Awagarh, District- Etah, State- Uttar Pradesh

Sample description

Source
of
Sample: SVD International School Jalesar Road Awagarh Etah

Village: Awagarh

Gram
Panchayat: AWAGARH

Block: Awagarh

District: Etah

State: Uttar Pradesh

Address:

Remarks: SVD International School Jalesar Road Awagarh Etah

Latitude: 27.45231

Longitude: 78.4686

Date & time of sample collection

25.03.2026 | 12:40:00 PM

Date & time of sample received in lab

25.03.2026 | 02:07:00 PM

Date & time of sample analysed

25.03.2026 | 02:20:00 PM

Date & time of report generation

|

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (In absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)*	mg/l	75	200	32.000	EDTA Titrimetric method	
2	Chloride (as Cl)*	mg/l	250	1000	40.000	Argentometric method	
3	Colour*	Hazen units	5	15	5.000	Spectrophotometric method	
4	Fluoride (as F)*	mg/l	1	1.5	0.500	Ion selective electrode method	
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.010	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
6	Magnesium (As Mg)*	mg/l	30	100	30.000	Calculation by APHA	
7	Nitrate (as NO ₃)*	mg/l	45	No Relaxation	1.800	UV-Visible Spectrophotometer	
8	pH*	NA	6.5-8.5	No Relaxation	7.050	Electrometric method	
9	Sulphate (as SO ₄)*	mg/l	200	400	24.000	Turbidimetric method	
10	TDS*	mg/l	500	2000	380.000	Gravimetric method	
11	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	128.000	Titration method	
12	Total Hardness (As CaCO ₃)*	mg/l	200	600	62.000	EDTA Titrimetric method	
13	Turbidity*	NTU	1	5	1.890	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report
- 5)This is not final approved report

Data prepared by
Chemist: (IMRAN ALI)

Authorised signatory
Aveesh Kumar Sharma (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home